

## Prime Water Electrodes

# DURABILITY

## PRIME WATER ELECTRODES Internal Durability Test Conducted

According to the analysis of the test results:

The tests were performed according to standard test methodology.

After each test was taken according to the different flow rates and comparing the analysis to a range of standards, even when not using the standard amounts, water cell life was ten years

- TEST conditions: H<sub>2</sub>SO<sub>4</sub> 0.5mol / l on the electrolyte solution 40 °C, 2A / d m<sup>2</sup> is current, 240hr electrolysis
- TEST Quantity: 3 varieties [Heat 1, Heat 2 times, Brazing products]
- TEST Date: 1/10 08:00
- TEST End Date: 20.01 08:00
- TEST progress results: 240hr after all

|    |          |      |
|----|----------|------|
| n= | 1 Pt 1 = | 0.22 |
| n= | 2 Pt 1 = | 0.18 |
| n= | 3 Pt 1 = | 0.20 |
| n= | 4 Pt 1 = | 0.19 |
| n= | 5 Pt 1 = | 0.14 |
| n= | 6 Pt 1 = | 0.18 |
| n= | 7 Pt 1 = | 0.21 |
| n= | 8 Pt 1 = | 0.20 |
| n= | 9 Pt 1 = | 0.21 |



|                    |       |
|--------------------|-------|
| Mean               | 0.190 |
| Standard deviation | 0.024 |
| C.O.V. (%)         | 12.85 |
| Range              | 0.08  |
| Number of readings | 9.0   |
| Min. reading       | 0.14  |
| Max. reading       | 0.14  |
| Measuring time     | 0.22  |
| Operator:          | 20    |

# Prime Water Electrodes Durability and Performance testing


| NO | Data                         | Descriptions   | Comments   |
|----|------------------------------|--|--|
| 1  | Product                      | Electrolytic Alkaline Water Generator<br>(Prime 1301 – 13Plates)   |  |
| 2  | Test Period                  | 40 days  | Daily Journal kept                               |
| 3  | Total Discharge              | 36,000 liters<br>(Four people using 10 L per day on average:<br>about 10 years worth)                                    | Standard - 365 day year                          |
| 4  | Basis of usage life          | At least 10 years over   |  |
| 5  | Water pressure               | 2.5 Kg/cm <sup>2</sup>   | Water pressure from unit                         |
| 6  | Water flow rate              | 2.5 l/min  | Alkaline water:1.5l/min<br>Acidic water:1.0l/min |
| 7  | This method                  | Every day five samples were taken to test pH and the average was taken down.   |  |
| 8  | This started cleaning method | The machine was used for 30 min. to produce alkaline water after which the machine went into cleaning cycle then tested. |  |
| 9  | Testing machine              | pH-meter Model:HM-20P Jejo Co.: TOA(Japan)   |  |

According to the analysis of the test results:

The tests were performed according to standard test methodology. After each test was taken according to the different flow rates and comparing the analysis to a range of standards, even when not using the standard amounts, water cell life was at least ten years over

# Prime Water Electrodes Durability and Performance testing

1~5 days test (0~4,500L)




|      | Tap Water pH       | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|------|--------------------|------------|------------|------------|------------|
| 1day | 1일차(~900ℓ)<br>7.8  | 8.5        | 9.0        | 9.5        | 10.0       |
| 2day | 2일차(~1800ℓ)<br>7.7 | 8.5        | 9.2        | 9.5        | 9.8        |
| 3day | 3일차(~2700ℓ)<br>7.8 | 8.7        | 9.3        | 9.6        | 9.9        |
| 4day | 4일차(~3600ℓ)<br>7.8 | 8.5        | 9.3        | 9.6        | 9.8        |
| 5day | 5일차(~4500ℓ)<br>7.7 | 8.6        | 9.3        | 9.6        | 9.9        |

- pH측정값은 5회를 실험정하여 나온 평균값으로 기재함.

# Prime Water Electrodes Durability and Performance testing

6~10 days test (4,500~9,000L)




|              | Tap Water pH | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|--------------|--------------|------------|------------|------------|------------|
| 6일자(~5400ℓ)  | 7.8          | 8.5        | 9.0        | 9.5        | 10.0       |
| 7일자(~6300ℓ)  | 7.7          | 8.6        | 9.1        | 9.5        | 9.8        |
| 8일자(~7200ℓ)  | 7.8          | 8.6        | 9.2        | 9.6        | 9.8        |
| 9일자(~8100ℓ)  | 7.7          | 8.5        | 9.1        | 9.5        | 9.8        |
| 10일자(~9000ℓ) | 7.7          | 8.6        | 9.1        | 9.6        | 9.9        |

- pH측정값은 5회를 실측정하여 나온 평균값으로 기재함.

# Prime Water Electrodes Durability and Performance testing

11~15 days test (9,000~13,500L)




|               | Tap Water pH | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|---------------|--------------|------------|------------|------------|------------|
| 11일자(~9900ℓ)  | 7.8          | 8.5        | 9.0        | 9.5        | 10.0       |
| 12일자(~10800ℓ) | 7.7          | 8.5        | 9.2        | 9.5        | 9.8        |
| 13일자(~11700ℓ) | 7.6          | 8.7        | 9.3        | 9.6        | 9.9        |
| 14일자(~12600ℓ) | 7.8          | 8.5        | 9.3        | 9.6        | 9.8        |
| 15일자(~13500ℓ) | 7.7          | 8.6        | 9.3        | 9.6        | 9.9        |

- pH측정값은 5회를 실측정하여 나온 평균값으로 기재함.

# Prime Water Electrodes Durability and Performance testing

16~20 days test (13,500~18,000L)




|               | Tap Water pH | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|---------------|--------------|------------|------------|------------|------------|
| 16일차(~14400ℓ) | 7.7          | 8.5        | 9.0        | 9.5        | 10.0       |
| 17일차(~15300ℓ) | 7.7          | 8.5        | 9.2        | 9.5        | 9.8        |
| 18일차(~16200ℓ) | 7.8          | 8.7        | 9.3        | 9.6        | 9.9        |
| 19일차(~17100ℓ) | 7.8          | 8.5        | 9.3        | 9.6        | 9.8        |
| 20일차(~18000ℓ) | 7.7          | 8.6        | 9.3        | 9.6        | 9.9        |

- pH측정값은 5회를 실측정하여 나온 평균값으로 기재함.



# Prime Water Electrodes Durability and Performance testing

21~25 days test (18,000~22,500L)




|               | Tap Water pH | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|---------------|--------------|------------|------------|------------|------------|
| 21일자(~18900L) | 7.8          | 8.5        | 9.0        | 9.5        | 10.0       |
| 22일자(~19800L) | 7.7          | 8.5        | 9.2        | 9.5        | 9.8        |
| 23일자(~20700L) | 7.8          | 8.7        | 9.3        | 9.6        | 9.9        |
| 24일자(~21600L) | 7.8          | 8.5        | 9.3        | 9.6        | 9.9        |
| 25일자(~22500L) | 7.7          | 8.6        | 9.3        | 9.6        | 9.9        |

- pH측정값은 5회를 실측정하여 나온 평균값으로 기재함.

# Prime Water Electrodes Durability and Performance testing

26~30 days test (22,500~27,000L)




|               | Tap Water pH | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|---------------|--------------|------------|------------|------------|------------|
| 26일차(~23400ℓ) | 7.8          | 8.5        | 9.0        | 9.5        | 10.0       |
| 27일차(~24300ℓ) | 7.7          | 8.5        | 9.2        | 9.5        | 9.8        |
| 28일차(~25200ℓ) | 7.8          | 8.6        | 9.2        | 9.5        | 9.98       |
| 29일차(~26100ℓ) | 7.7          | 8.5        | 9.3        | 9.6        | 9.8        |
| 30일차(~27000ℓ) | 7.7          | 8.6        | 9.2        | 9.5        | 9.9        |

- pH측정값은 5회를 실측정하여 나온 평균값으로 기재함.



# Prime Water Electrodes Durability and Performance testing

31~35 days test (27,900~31,500L)




|               | Tap Water pH | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|---------------|--------------|------------|------------|------------|------------|
| 31일자(~27900L) | 7.8          | 8.5        | 9.0        | 9.5        | 9.9        |
| 32일자(~28800L) | 7.8          | 8.5        | 9.2        | 9.5        | 9.8        |
| 33일자(~29700L) | 7.8          | 8.4        | 9.1        | 9.5        | 9.8        |
| 34일자(~30600L) | 7.8          | 8.5        | 9.3        | 9.4        | 9.8        |
| 35일자(~31500L) | 7.7          | 8.5        | 9.0        | 9.5        | 9.8        |

- pH측정값은 5회를 실측정하여 나온 평균값으로 기재함.

# Prime Water Electrodes Durability and Performance testing




36~40 days test (31,500~36,000L)




|              | Tap Water pH | Alkaline-1 | Alkaline-2 | Alkaline-3 | Alkaline-4 |
|--------------|--------------|------------|------------|------------|------------|
| 36일자(~32400) | 7.8          | 8.4        | 9.0        | 9.5        | 9.8        |
| 37일자(~33300) | 7.7          | 8.5        | 8.9        | 9.5        | 9.8        |
| 38일자(~34200) | 7.8          | 8.4        | 9.0        | 9.4        | 9.8        |
| 39일자(~35100) | 7.8          | 8.5        | 9.0        | 9.6        | 9.8        |
| 40일자(~36000) | 7.7          | 8.4        | 9.1        | 9.6        | 9.9        |

- pH측정값은 5회를 실험정하여, 나온 평균값으로 기재함.

# Prime Water Electrodes Durability and Performance testing

| Company  | 3D Surface roughness measure   | Result  |
|--|--|---|
| <p style="text-align: center;"><b>CHINA<br/>PLATES</b></p>                 |  <p><b>Veeco 3-Dimensional Interactive Display</b> Date: 10/07/201 Time: 09:37:56</p> <p><b>Surface Stats:</b><br/>           Ra: 1.45 um<br/>           Rq: 1.84 um<br/>           Rt: 16.45 um<br/>           Rz: 15.27 um</p> <p><b>Measurement Info:</b><br/>           Magnification: 25.33<br/>           Measurement Mode: VSI<br/>           Sampling: 331.58 nm<br/>           Array Size: 736 X 480</p>    | <p style="text-align: center;"><b>Surface roughness :<br/>rough</b></p>       |
| <p style="text-align: center;"><b>KOREA "A"<br/>COMPANY<br/>PLATES</b></p> |  <p><b>Veeco 3-Dimensional Interactive Display</b> Date: 09/07/201 Time: 10:11:17</p> <p><b>Surface Stats:</b><br/>           Ra: 1.91 um<br/>           Rq: 2.43 um<br/>           Rt: 22.05 um<br/>           Rz: 20.03 um</p> <p><b>Measurement Info:</b><br/>           Magnification: 25.33<br/>           Measurement Mode: VSI<br/>           Sampling: 331.58 nm<br/>           Array Size: 736 X 480</p>    | <p style="text-align: center;"><b>Surface roughness :<br/>rough</b></p>       |
| <p style="text-align: center;"><b>PRIME<br/>WATER<br/>PLATES</b></p>       |  <p><b>Veeco 3-Dimensional Interactive Display</b> Date: 09/07/201 Time: 10:05:00</p> <p><b>Surface Stats:</b><br/>           Ra: 0.0913 um<br/>           Rq: 1.17 um<br/>           Rt: 16.35 um<br/>           Rz: 11.51 um</p> <p><b>Measurement Info:</b><br/>           Magnification: 25.33<br/>           Measurement Mode: VSI<br/>           Sampling: 331.58 nm<br/>           Array Size: 736 X 480</p> | <p style="text-align: center;"><b>Surface roughness<br/>:Good surface</b></p> |

## Prime Water Electrodes Surface



## ■ Platinum Plating Process



### Press

Titanium shape processing in the press



### Electrode machining

Electrode cutting and rolling process



### Washing

Removal of oil and grease from media and cut pieces



### Spot Weding

Welding of the metal terminal to the electrode.



### Sanding

Sand blasting process to improve plating adhesion



### Racking

Titanium electrodes loaded onto plating jig





**Packing/Shipping**

**Skimmer**

Removal of any surface grease or oil

**Etching**

Removal of oxidation from titanium surface

**Activator**

Surface of titanium activated to improve plating adhesion

**Platinum Plating**

Titanium plated with platinum

**Drying**

Water is removed from the surface of the platinum

**Heat Treatment**

Heat treated in furnace to strengthen adhesion of platinum  
To titanium.

**Shipping Inspection**

Reliability and appearance inspection /  
Certificate of Inspection issued